



From

Executive Engineer,
Provincial Division No.2,
PWD B&R Br., Rohtak.

To

Dr. Vikas Siwach,
Chairman,
Vidya Shree International School,
6th Mile Stone, Sonapat Road,
Rohtak.

Memo No. 9801

Dated 23/07/2018

Subject: - Issue of certificate regarding Structurally safe building for Vidya Shree International School, Rohtak.

Reference:- Your letter dated 13.06.2018.

In this connection, it is submitted that after visual inspection of the above school building by SDE incharge alongwith concerned JE and school authority found facts as under:

1. Building has been constructed as frame structure, only two storey work has been completed and for balance stories work is in progress.
2. Plint level is about 2' to 2 ½ ' above road level.
3. There is no crack visible in existing building.
4. Construction of building is frame type structure.
5. No rain harvesting system has been adopted as per building by laws.
6. No solar system has been adopted as per building by laws.
7. Fire fighting system adopted at site.

Hence it is certified that the school building is seems to be structurally safe.

DA/- Nil


Executive Engineer,
Provincial Division No.2,
PWD B&R Br., Rohtak.